

# VOC Content Test Certificate

Friday August 20<sup>th</sup>, 2010

Manufacturer: Permoseal Pty Ltd (Beverley Close, Montague Gardens, 7441, South Africa)

Sample Description: Hi-Tack Eco Green

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of South Africa</b>  <b>Africa Green Star SA Office V1</b>	<b>Hi-Tack Eco Green</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>48 grams per Litre as VOC content          per material</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**F1008-02**