

VOC Content Test Certificate

Friday August 20th, 2010

Manufacturer: Permoseal Pty Ltd (Beverley Close, Montague Gardens, 7441, South Africa)

Sample Description: Hi-Tack

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of South Africa Africa Green Star SA Office V1	Hi-Tack
Architectural Sealant 250 grams per Litre as VOC content material	24 grams per Litre as VOC content per material



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F1008-02